

DATE:

CHECKED:

HBP-2000-4-3 BLOWER PURGE DESICCANT AIR DRYER GENERAL ARRANGEMENT

SHEET: 1 OF 2

DRAWING NO.

SCALE: N/A

AT20-1143

REV.

TOLERANCES UNLESS OTHERWISE SPECIFIED:

FRACTIONS =± 1/4 "

ANGLES = \pm 3° INCHES = \pm 1/2 "


FINISH = 250


THE SPECIFICATIONS AND DRAWINGS DISCLOSED HEREIN ARE THE SOLE PROPERTY OF ALTEC AIR, AND SHALL NOT BE COPIED OR USED AS THE BASIS FOR SALE OR MANUFACTURE WITHOUT EXPRESS WRITTEN PERMISSION.


REVISION LOG


REV. ECO. DESCRIPTION DATE APPROVED

A









PRELIMINARY



DATE:

CHECKED:

HBP-2000-4-3 BLOWER PURGE DESICCANT AIR DRYER GENERAL ARRANGEMENT

DRAWING NO.

SCALE: N/A

AT20-1143

SHEET: 2 OF 2

TOLERANCES UNLESS OTHERWISE SPECIFIED:

FRACTIONS =± 1/4 "

ANGLES = \pm 3° INCHES = \pm 1/2 "

FINISH = 250

REV.

THE SPECIFICATIONS AND DRAWINGS DISCLOSED HEREIN ARE THE SOLE PROPERTY OF ALTEC AIR, AND SHALL NOT BE COPIED OR USED AS THE BASIS FOR SALE OR MANUFACTURE WITHOUT EXPRESS WRITTEN PERMISSION.

REVISION LOG

REV. ECO. DESCRIPTION DATE APPROVED

	1
3 5	1 1 1 1
4 9 11 4 12 12 12 12 12 12 12 12 12 12 12 12 12	1 1 1 2 2
	2: 2:

PARTS LIST				
TEM	QTY	DESCRIPTION		
1	2	CHECK VALVE, PURGE		
2	2	CHECK VALVE, OUTLET		
3	1	SOLENOID VALVE, REPRESS		
4	1	PARTICULATE FILTER, CONTROL		
5	1	MOISTURE INDICATOR		
6	1	PRESSURE REGULATOR, CONTROL		
7	1	PRESSURE GAUGE, CONTROL		
8	1	DEW POINT MONITOR (OPTIONAL)		
9	1	SOLENOID VALVE, 2%		
10	1	CHECK VALVE, BLOWER		
11	4	RELIEF VALVE, TANK		
12	1	30 KW HEATER		
13	2	PRESSURE GAUGE, TANK		
14	1	COALESCER PRE-FILTER		
15	1	ZERO LOSS DRAIN		
16	1	7 1/2 HP BLOWER		
17	1	FILTER, BLOWER		
18	2	BUTTERFLY VALVE, INLET		
19	2	BUTTERFLY VALVE, EXHAUST		
20	2	ANGLE BODY VALVE, PRE-EXHAUST		
21	2	MUFFLER, PRE-EXHAUST		
22	1	PARTICULATE AFTER-FILTER		
23	3	MANUAL BUTTERFLY VALVE, BYPASS		
24	2800 LBS	DESICCANT		

PRELIMINARY